

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-K-2101A-VALVE-INSPECTION Revision: A
Title: Valve inspection, recycle gas compressor K-2101A
Owner: Gopal Iyer
Issued: 25 July 2026

Primary equipment: K-2101A, Recycle gas compressor A

Inspector: Gopal Iyer
Equipment: K-2101A

Findings. Second stage discharge valve plates showed light wear. Rod load readings 162 kN.
Packing leakage within limits. Result: satisfactory, next valve inspection in 4,000 hours.