

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-P-3101A-BEARING-CONDITION Revision: A
Title: Bearing condition report, cooling water pump P-3101A
Owner: Gopal Iyer
Issued: 24 August 2026

Primary equipment: P-3101A, Cooling water pump A

Inspector: Gopal Iyer
Equipment: P-3101A

Findings. Drive end bearing temperature 78 degC at rated load, vibration 3.1 mm/s. Oil sample clean. Result: satisfactory.