

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-PSV-1101-BENCH-TEST Revision: A
Title: Bench test record, pressure safety valve PSV-1101
Owner: Gopal Iyer
Issued: 17 March 2026

Primary equipment: PSV-1101, Pressure safety valve 1

Inspector: Gopal Iyer
Equipment: PSV-1101

Findings. As-found lift pressure 17.6 barg against a set pressure of 18.0 barg, within the 3 percent tolerance. Valve reset and sealed. Next bench test due in 24 months. Result: passed.