

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-PSV-1102-BENCH-TEST Revision: A
Title: Bench test record, pressure safety valve PSV-1102
Owner: Gopal Iyer
Issued: 20 July 2026

Primary equipment: PSV-1102, Pressure safety valve 2

Inspector: Gopal Iyer
Equipment: PSV-1102

Findings. As-found lift pressure 19.4 barg against a set pressure of 18.0 barg, outside tolerance. Seat lapped and retested at 18.1 barg. Result: failed as found, passed after repair.