

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-PSV-2101-BENCH-TEST Revision: A
Title: Bench test record, pressure safety valve PSV-2101
Owner: Gopal Iyer
Issued: 06 April 2026

Primary equipment: PSV-2101, Reactor relief valve 1

Inspector: Gopal Iyer
Equipment: PSV-2101

Findings. As-found lift 101.5 barg, set pressure 100.0 barg, within tolerance. Result: passed.