

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-PSV-3101-BENCH-TEST Revision: A
Title: Bench test record, steam drum relief valve PSV-3101
Owner: Gopal Iyer
Issued: 26 April 2026

Primary equipment: PSV-3101, Steam drum relief valve 1

Inspector: Gopal Iyer
Equipment: PSV-3101

Findings. As-found lift 41.2 barg, set pressure 40.0 barg, within tolerance. Reset and sealed.
Result: passed.