

Veridian Petrochemicals
Dahej Tank Farm

Document no: INSP-T-6101-EXTERNAL-INSPECTION Revision: A
Title: Annual external inspection of tank T-6101
Owner: Gopal Iyer
Issued: 04 August 2026

Primary equipment: T-6101, Product storage tank 1

Inspector: Gopal Iyer
Equipment: T-6101

Findings. Shell settlement within 25 mm limit. Radar gauge reads within 8 mm of the manual dip. Vent relief valve PSV-6101 tagged and in date. Result: satisfactory.