

Veridian Petrochemicals
Dahej Tank Farm

Document no: INSP-T-6102-FLOOR-SURVEY Revision: A
Title: Floor survey of tank T-6102
Owner: Gopal Iyer
Issued: 25 June 2026

Primary equipment: T-6102, Product storage tank 2

Inspector: Gopal Iyer
Equipment: T-6102

Findings. Floor plate loss up to 1.6 mm near the sump. Coating breakdown on 12 percent of the floor area. Result: conditional, recoat at the next outage.