

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-V-2101-INTERNAL-INSPECTION Revision: A
Title: Internal inspection of hot high pressure separator V-2101
Owner: Gopal Iyer
Issued: 30 June 2026

Primary equipment: V-2101, Hot high pressure separator

Inspector: Gopal Iyer
Equipment: V-2101

Findings. Weld seams examined by magnetic particle testing; no linear indications. General corrosion 0.9 mm since last inspection. Demister pad replaced. Result: satisfactory.