

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-XV-1102-STROKE-TEST Revision: A
Title: Stroke test record, emergency isolation valve XV-1102
Owner: Gopal Iyer
Issued: 25 February 2026

Primary equipment: XV-1102, Emergency isolation valve 2

Inspector: Gopal Iyer
Equipment: XV-1102

Findings. Closure time 6.4 seconds against the 8 second limit. No leakage on the seat test.
Result: passed.