

Veridian Petrochemicals
Dahej Tank Farm

Document no: INSP-XV-6101-LEAK-TEST Revision: A
Title: Leak test, tank outlet valve XV-6101
Owner: Gopal Iyer
Issued: 09 August 2026

Primary equipment: XV-6101, Tank outlet valve 1

Inspector: Gopal Iyer
Equipment: XV-6101

Findings. Seat leakage rate class IV achieved. Actuator travel confirmed. Result: passed.