

Veridian Petrochemicals
Bharuch Complex

Document no: KHT-SB-2026-03-CLEANING-INTERVAL Revision: A
Title: Karvel Heat Transfer service bulletin: cleaning interval for E-1101
Owner: Karvel Heat Transfer
Issued: 22 August 2026

Primary equipment: E-1101, Crude preheat exchanger 1

Service bulletin KHT-SB-2026 revision A, issued by Karvel Heat Transfer.

Subject. Revision of the cleaning interval for E-1101.

The previously published value of 24 months is withdrawn. The cleaning interval for E-1101 is now 18 months. Operators must update site procedures and records that quote the old value. This bulletin supersedes the value in the operation manual.