

Veridian Petrochemicals
Bharuch Complex

Document no: KHT-STX-MM Revision: B
Title: Maintenance manual, KHT-STX shell and tube exchangers
Owner: Dr. Sunita Rao
Issued: 03 December 2022

Primary equipment: E-1101, Crude preheat exchanger 1

Applies to the crude preheat train E-1101 to E-1106, overhead condensers E-1107A to E-1107D and the HDT feed effluent exchangers E-2101 to E-2105. Fixed tubesheet with expansion joint, carbon steel shell, tubes in 304L. Hydrotest at 1.3 times design pressure. Recommended cleaning interval 24 months, shortened where the fouling factor exceeds 0.0006 m²K/W.