

Veridian Petrochemicals  
Bharuch Complex

Document no: MAINT-XV-3103-2026 Revision: A  
Title: Maintenance history card, XV-3103  
Owner: Neha Kulkarni  
Issued: 23 August 2026

Primary equipment: XV-3103, Steam isolation valve 3

30 June 2026: Stroke test, completed by Dinesh Patel. No defects found.

05 March 2026: Actuator inspection, completed by Dinesh Patel. No defects found.

26 December 2025: Solenoid check, completed by Dinesh Patel. No defects found.

Next preventive maintenance is raised by the planner.