

Veridian Petrochemicals
Bharuch Complex

Document no: OEM-V-2101-DESIGN-REVISION Revision: A
Title: Halden Fluid Systems service bulletin: corrosion allowance for V-2101
Owner: Halden Fluid Systems
Issued: 28 August 2026

Primary equipment: V-2101, Hot high pressure separator

Service bulletin HFS-SB-2026 revision A, issued by Halden Fluid Systems.

Subject. Revision of the corrosion allowance for V-2101.

The previously published value of 3.0 mm is withdrawn. The corrosion allowance for V-2101 is now 2.5 mm. Operators must update site procedures and records that quote the old value. This bulletin supersedes the value in the operation manual.