

Veridian Petrochemicals
Dahej Tank Farm

Document no: OTS-SB-2026-08-FILL-LEVEL Revision: A
Title: Orbis Tank Systems service bulletin: maximum fill level for T-6101
Owner: Orbis Tank Systems
Issued: 04 August 2026

Primary equipment: T-6101, Product storage tank 1

Service bulletin OTS-SB-2026 revision A, issued by Orbis Tank Systems.

Subject. Revision of the maximum fill level for T-6101.

The previously published value of 92 percent is withdrawn. The maximum fill level for T-6101 is now 88 percent. Operators must update site procedures and records that quote the old value. This bulletin supersedes the value in the operation manual.