

Veridian Petrochemicals
Dahej Tank Farm

Document no: REG-STORAGE-TANK-OPERATION-SUMMARY Revision: A
Title: Storage tank operation, statutory summary
Owner: Compliance register
Issued: 02 November 2024

Primary equipment: T-6101, Product storage tank 1

Summary of statutory requirements.

Flammable liquid tanks must have independent overfill protection, a tested vent relief valve and a fire water supply. Gauging equipment is checked at least weekly and the results recorded.