

Veridian Petrochemicals
Bharuch Complex

Document no: REG-WORK-PERMIT-SYSTEM-SUMMARY Revision: A
Title: Work permit system, statutory summary
Owner: Compliance register
Issued: 02 November 2024

Primary equipment: XV-1101, Emergency isolation valve 1

Summary of statutory requirements.

Hot work, confined space entry and high pressure line breaking require a written permit to work issued by an authorised issuer. The permit names the equipment, the isolation boundary and the person receiving it. Two independent signatures are required before safety-critical work begins. Permits are kept for three years.