

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-CDU-ESD-VALVE-TESTING Revision: C
Title: Operating procedure: emergency isolation valve XV-1102
Owner: Prakash Menon
Issued: 29 April 2025

Primary equipment: XV-1102, Emergency isolation valve 2

Purpose. This procedure covers the emergency isolation valve XV-1102.

Requirement. Stroke test XV-1102 every 12 months and record the closure time against the 8 second limit.

Responsibility. The shift lead of the CDU unit is responsible for compliance with this procedure; deviations are reported to the process engineer.