

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-CDU-PSV-TEST-AND-RESET Revision: C

Title: Operating procedure: pressure safety valve PSV-1101 on the atmospheric column C-1101

Owner: Prakash Menon

Issued: 23 July 2025

Primary equipment: PSV-1101, Pressure safety valve 1

Purpose. This procedure covers the pressure safety valve PSV-1101 on the atmospheric column C-1101.

Requirement. Bench test and reset PSV-1101 at a set pressure of 18.0 barg. After reset record the lift pressure and the reseal pressure.

Responsibility. The shift lead of the CDU unit is responsible for compliance with this procedure; deviations are reported to the process engineer.