

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-CDU-ISOLATION-AND-LOCKOUT Revision: B
Title: Isolation and lockout for CDU pumps
Owner: Rohit Bhatt
Issued: 29 September 2025

Primary equipment: XV-1101, Emergency isolation valve 1

Purpose. Isolation and lockout for CDU pumps.

Method. Isolate pumps P-1101A, P-1101B, P-1102A and P-1102B by closing the suction and discharge valves, locking out the motor breaker and draining the casing. Two people verify the isolation before a permit to work is issued. Emergency isolation valves XV-1101 to XV-1104 are tested separately.