

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-CDU-PUMP-CHANGEOVER Revision: B
Title: Changeover of crude feed pumps P-1101A and P-1101B
Owner: Kiran Joshi
Issued: 22 October 2025

Primary equipment: P-1101B, Crude feed pump B

Purpose. Changeover of crude feed pumps P-1101A and P-1101B.

Method. Start the standby pump P-1101B, confirm discharge pressure and flow, then stop P-1101A slowly closing its discharge valve. Check the seal barrier pressure on the pump that has stopped. Changeover must be logged in the shift log.