

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-CDU-SHUTDOWN-SEQUENCE Revision: B
Title: Normal shutdown of the crude distillation unit
Owner: Prakash Menon
Issued: 14 November 2025

Primary equipment: P-1101A, Crude feed pump A

Purpose. Normal shutdown of the crude distillation unit.

Method. Reduce charge rate to 60 percent, cool the heater at 40 degC per hour, stop P-1101A last. Drain the desalter V-1101 interface before isolation. The shift lead signs the shutdown log.