

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-HDT-CHARGE-PUMP-OPERATION Revision: B
Title: Operation of reactor charge pumps P-2101A and P-2101B
Owner: Lata Deshmukh
Issued: 14 August 2025

Primary equipment: P-2101A, Reactor charge pump A

Purpose. Operation of reactor charge pumps P-2101A and P-2101B.

Method. Warm the pump casing at no more than 50 degC per hour. Start only against a minimum flow line open. Check the tandem seal pot level every shift. A vibration above 4.5 mm/s requires a work order.