

Veridian Petrochemicals
Dahej Tank Farm

Document no: SOP-TKF-FIRE-WATER-TESTING Revision: B
Title: Weekly fire water pump test
Owner: Rohit Bhatt
Issued: 14 May 2025

Primary equipment: P-6201B, Fire water pump B

Purpose. Weekly fire water pump test.

Method. Run each diesel-driven fire water pump P-6201A, P-6201B and P-6201C for 30 minutes at rated speed every week. Record the discharge pressure, the engine oil pressure and the fuel level.