

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-UTL-COOLING-WATER-CHANGEOVER Revision: B
Title: Cooling water pump changeover
Owner: Meera Pillai
Issued: 29 June 2025

Primary equipment: P-3101B, Cooling water pump B

Purpose. Cooling water pump changeover.

Method. Three cooling water pumps P-3101A, P-3101B and P-3101C serve the plant; two run and one is standby. Rotate the standby every month. Record header pressure before and after.