

Veridian Petrochemicals
Bharuch Complex

Document no: SOP-UTL-COOLING-WATER-PUMP-OPERATION Revision: C
Title: Operating procedure: cooling water pump P-3101A
Owner: Prakash Menon
Issued: 12 April 2025

Primary equipment: P-3101A, Cooling water pump A

Purpose. This procedure covers the cooling water pump P-3101A.

Requirement. Raise a work order if the bearing temperature of P-3101A exceeds 85 degC.

Responsibility. The shift lead of the UTL unit is responsible for compliance with this procedure; deviations are reported to the process engineer.