

Veridian Petrochemicals
Bharuch Complex

Document no: SVW-9-MM Revision: C
Title: Maintenance manual, SVW-9 series pressure safety valves
Owner: Dr. Sunita Rao
Issued: 21 June 2023

Primary equipment: PSV-1101, Pressure safety valve 1

Applies to PSV-1101 to PSV-1104 (CDU), PSV-2101 to PSV-2103 (HDT), PSV-3101 and PSV-3102 (steam drum) and PSV-4101 (flare header). Spring-loaded, balanced bellows. Set pressure tolerance plus or minus 3 percent. Bench test and reset every 24 months; stroke test of the lifting lever annually. Blowdown 7 percent.