

Veridian Petrochemicals
Bharuch Complex

Document no: SVW-SB-2026-04-ESD-VALVE-TEST-INTERVAL Revision: A
Title: Calder Controls service bulletin: stroke test interval for XV-1102
Owner: Calder Controls
Issued: 10 August 2026

Primary equipment: XV-1102, Emergency isolation valve 2

Service bulletin CLC-SB-2026 revision A, issued by Calder Controls.

Subject. Revision of the stroke test interval for XV-1102.

The previously published value of 12 months is withdrawn. The stroke test interval for XV-1102 is now 6 months. Operators must update site procedures and records that quote the old value. This bulletin supersedes the value in the operation manual.