

Veridian Petrochemicals
Bharuch Complex

Document no: SVW-SB-2026-07-PSV-SET-PRESSURE Revision: A
Title: Halden Fluid Systems service bulletin: set pressure for PSV-1101
Owner: Halden Fluid Systems
Issued: 11 July 2026

Primary equipment: PSV-1101, Pressure safety valve 1

Service bulletin HFS-SB-2026 revision A, issued by Halden Fluid Systems.

Subject. Revision of the set pressure for PSV-1101.

The previously published value of 18.0 barg is withdrawn. The set pressure for PSV-1101 is now 16.8 barg. Operators must update site procedures and records that quote the old value. This bulletin supersedes the value in the operation manual.