

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-B-3101-2025 Revision: A
Title: Burner and tube inspection, B-3101
Owner: Gopal Iyer
Issued: 29 December 2025

Primary equipment: B-3101, Package boiler

Tester: Gopal Iyer
Equipment: B-3101

Burner tips cleaned and flames stable.
Tube thermography completed, no hot spots.
Refractory in sound condition.
Result: passed with an observation.