

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-C-2101-2026 Revision: A
Title: External inspection and thickness survey, C-2101
Owner: Gopal Iyer
Issued: 05 June 2026

Primary equipment: C-2101, Amine absorber

Tester: Gopal Iyer
Equipment: C-2101

Minimum measured wall 11.1 mm at the survey points.
No active leaks, coating in sound condition.
Supports, nozzles and platforms examined.
Result: passed.