

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-C-2102-2025 Revision: A
Title: External inspection and thickness survey, C-2102
Owner: Gopal Iyer
Issued: 24 December 2025

Primary equipment: C-2102, Product stripper

Tester: Gopal Iyer
Equipment: C-2102

Minimum measured wall 19.4 mm at the survey points.
No active leaks, coating in sound condition.
Supports, nozzles and platforms examined.
Result: passed.