

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-FV-1102-2025 Revision: A
Title: Stroke and positioner calibration, FV-1102
Owner: Gopal Iyer
Issued: 07 November 2025

Primary equipment: FV-1102, Flow control valve 2

Tester: Gopal Iyer
Equipment: FV-1102

Hysteresis 0.37 percent of span.
Full stroke travel confirmed at 0, 50 and 100 percent.
Positioner re-tuned and a signature recorded.
Result: passed.