

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-FV-1103-2025 Revision: A
Title: Stroke and positioner calibration, FV-1103
Owner: Gopal Iyer
Issued: 10 December 2025

Primary equipment: FV-1103, Flow control valve 3

Tester: Gopal Iyer
Equipment: FV-1103

Hysteresis 0.39 percent of span.
Full stroke travel confirmed at 0, 50 and 100 percent.
Positioner re-tuned and a signature recorded.
Result: passed.