

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-FV-1104-2025 Revision: A
Title: Stroke and positioner calibration, FV-1104
Owner: Gopal Iyer
Issued: 13 October 2025

Primary equipment: FV-1104, Flow control valve 4

Tester: Gopal Iyer
Equipment: FV-1104

Hysteresis 0.50 percent of span.
Full stroke travel confirmed at 0, 50 and 100 percent.
Positioner re-tuned and a signature recorded.
Result: passed.