

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-FV-1106-2025 Revision: A
Title: Stroke and positioner calibration, FV-1106
Owner: Gopal Iyer
Issued: 29 October 2025

Primary equipment: FV-1106, Flow control valve 6

Tester: Gopal Iyer
Equipment: FV-1106

Hysteresis 0.48 percent of span.
Full stroke travel confirmed at 0, 50 and 100 percent.
Positioner re-tuned and a signature recorded.
Result: passed.