

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-FV-2101-2026 Revision: A
Title: Stroke and positioner calibration, FV-2101
Owner: Gopal Iyer
Issued: 14 January 2026

Primary equipment: FV-2101, Hydrogen control valve 1

Tester: Gopal Iyer
Equipment: FV-2101

Hysteresis 0.55 percent of span.
Full stroke travel confirmed at 0, 50 and 100 percent.
Positioner re-tuned and a signature recorded.
Result: passed.