

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-FV-2102-2026 Revision: A
Title: Stroke and positioner calibration, FV-2102
Owner: Gopal Iyer
Issued: 16 February 2026

Primary equipment: FV-2102, Hydrogen control valve 2

Tester: Gopal Iyer
Equipment: FV-2102

Hysteresis 0.55 percent of span.
Full stroke travel confirmed at 0, 50 and 100 percent.
Positioner re-tuned and a signature recorded.
Result: passed.