

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-FV-2103-2025 Revision: A
Title: Stroke and positioner calibration, FV-2103
Owner: Gopal Iyer
Issued: 01 October 2025

Primary equipment: FV-2103, Hydrogen control valve 3

Tester: Gopal Iyer
Equipment: FV-2103

Hysteresis 0.40 percent of span.
Full stroke travel confirmed at 0, 50 and 100 percent.
Positioner re-tuned and a signature recorded.
Result: passed.