

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-H-2101-2026 Revision: A
Title: Burner and tube inspection, H-2101
Owner: Gopal Iyer
Issued: 13 April 2026

Primary equipment: H-2101, Reactor charge heater

Tester: Gopal Iyer
Equipment: H-2101

Burner tips cleaned and flames stable.
Tube thermography completed, no hot spots.
Refractory in sound condition.
Result: passed.