

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-K-2101B-2026 Revision: A
Title: Condition test, K-2101B
Owner: Gopal Iyer
Issued: 06 July 2026

Primary equipment: K-2101B, Recycle gas compressor B

Tester: Gopal Iyer
Equipment: K-2101B

Frame vibration 5.8 mm/s RMS.
Cylinder discharge temperature 105 degC.
Lube oil pressure steady.
Rod drop within the packing records.
Result: passed.