

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-K-3101A-2025 Revision: A
Title: Condition test, K-3101A
Owner: Gopal Iyer
Issued: 08 September 2025

Primary equipment: K-3101A, Instrument air compressor A

Tester: Gopal Iyer
Equipment: K-3101A

Frame vibration 6.9 mm/s RMS.
Cylinder discharge temperature 94 degC.
Lube oil pressure steady.
Rod drop within the packing records.
Result: passed.