

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-K-3101B-2026 Revision: A
Title: Condition test, K-3101B
Owner: Gopal Iyer
Issued: 07 July 2026

Primary equipment: K-3101B, Instrument air compressor B

Tester: Gopal Iyer
Equipment: K-3101B

Frame vibration 7.3 mm/s RMS.
Cylinder discharge temperature 103 degC.
Lube oil pressure steady.
Rod drop within the packing records.
Result: passed.