

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-LA-5102-2026 Revision: A
Title: Inspection and function test, LA-5102
Owner: Gopal Iyer
Issued: 05 February 2026

Primary equipment: LA-5102, Loading arm 2

Tester: Gopal Iyer
Equipment: LA-5102

Swivel joints free, no seep from the seals.
Earthing monitor and overfill probe tested.
Counterbalance within the arm travel.
Result: passed.