

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-LA-5104-2025 Revision: A
Title: Inspection and function test, LA-5104
Owner: Gopal Iyer
Issued: 07 September 2025

Primary equipment: LA-5104, Loading arm 4

Tester: Gopal Iyer
Equipment: LA-5104

Swivel joints free, no seep from the seals.
Earthing monitor and overfill probe tested.
Counterbalance within the arm travel.
Result: passed with an observation.