

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-LT-1101-2026 Revision: A
Title: Calibration record, LT-1101
Owner: Gopal Iyer
Issued: 17 March 2026

Primary equipment: LT-1101, Column bottom level

Tester: Gopal Iyer
Equipment: LT-1101

As-found error 0.18 percent of span.
As-left error 0.02 percent of span.
Loop check and tag confirmed.
Result: passed.