

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-LT-1102-2026 Revision: A
Title: Calibration record, LT-1102
Owner: Gopal Iyer
Issued: 27 July 2026

Primary equipment: LT-1102, Desalter interface level

Tester: Gopal Iyer
Equipment: LT-1102

As-found error 0.24 percent of span.
As-left error 0.02 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.