

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-LT-1103-2025 Revision: A
Title: Calibration record, LT-1103
Owner: Gopal Iyer
Issued: 31 December 2025

Primary equipment: LT-1103, Reflux drum level

Tester: Gopal Iyer
Equipment: LT-1103

As-found error 0.10 percent of span.
As-left error 0.04 percent of span.
Loop check and tag confirmed.
Result: passed.