

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-LT-4101-2025 Revision: A
Title: Calibration record, LT-4101
Owner: Gopal Iyer
Issued: 08 October 2025

Primary equipment: LT-4101, Knock-out drum level

Tester: Gopal Iyer
Equipment: LT-4101

As-found error 0.07 percent of span.
As-left error 0.03 percent of span.
Loop check and tag confirmed.
Result: passed.